



Retlif Testing Laboratories

795 Marconi Avenue, Ronkonkoma, NY 11779
631-737-1500 - Fax: 631-737-1497

BRANCH LABORATORIES
101 New Boston Road
Goffstown, NH 03045
603-487-4800 Fax 603-487-5281
WASHINGTON
REGULATORY OFFICE
703-633-1614 Fax 703-633-1612

December 3, 2002

Utility Relay Company
16759 West Park Circle Drive
Chagrin Falls, Ohio 44023

Dear Mr. Helmut Weiher:

Enclosed you will find Retlif Testing Laboratories Report R-9699 covering the electromagnetic compatibility testing which was performed on your Zero-Hertz Protective Relay, Part Number B-203-SP2. This testing was performed and test report generated in accordance with your Purchase Order Number VRC 7272.

Thank you for the opportunity to be of service to you. Should you have any questions regarding the enclosed report or the actual testing of your sample, please do not hesitate to contact me.

Sincerely,

Retlif Testing Laboratories

Michelle White
Administrative Coordinator
nyemclab@retlif.com

Enc. (as stated)



Retlif Testing Laboratories

795 Marconi Avenue, Ronkonkoma, NY 11779
631-737-1500 - Fax: 631-737-1497

BRANCH LABORATORIES
101 New Boston Road
Goffstown, NH 03045
603-497-4800 Fax 603-487-6281
WASHINGTON
REGULATORY OFFICE
703-533-1814 Fax 703-533-1612

Electromagnetic Compatibility Test Report

For

Zero-Hertz Protective Relay

Part Number: B-203-SP2

CUSTOMER NAME: Utility Relay Company

CUSTOMER P.O.: VRC 7272

DATE OF REPORT: November 19, 2002

TEST REPORT NO.: R-9699

TEST START DATE: November 18, 2002

TEST FINISH DATE: November 18, 2002

TEST TECHNICIAN: S. Carley

TEST ENGINEER: R. Warren

SUPERVISOR: R. J. Reitz

REPORT PREPARED BY: M. White

Our letters and reports are for the exclusive use of the customer to whom they are addressed and their communication or the use of the name of RETLIF TESTING LABORATORIES must receive our prior written approval. Our letters and reports apply only to the sample tested and are not necessarily indicative of the qualities of apparently identical or similar products. The reports and letters and the name of RETLIF TESTING LABORATORIES or insignia are not to be used under any circumstances in advertising to the public. This report shall not be reproduced, except in full, without the prior written approval of RETLIF TESTING LABORATORIES, INC. The only official copy of this document is the signed original provided by Retlif Testing Laboratories, Inc.

Table of Contents

<i>Table of Contents</i>	2
<i>Certification and Signatures</i>	3
<i>Test Program Summary</i>	4
<i>Revision History</i>	5
1.0 Scope	6
2.0 Applicable Documents	6
3.0 General Requirements	7
3.1 Test Environment	7
3.1.1 Shielded Enclosures	7
3.1.2 RF Absorber Material	7
3.1.3 Ground Plane	7
3.2 Test Instrumentation	7
3.2.1 Grounding	7
3.2.2 Measurement Accuracy	7
4.0 Test Sample Description	8
4.1 General	8
4.2 Configuration	8
5.0 Test Sample Parameters	10
5.1 Mode of Operation	10
5.1.1 Support Equipment	10
5.2 Performance Requirements	10
5.2.1 Monitoring Equipment	10
6.0 Test Methods	11
6.1 Radiated RF Susceptibility, 450 MHz	12
6.2 Dielectric Tests	17
6.3 Surge Test	21




Retlif Testing Laboratories


Test Report No. R-9699

Certification and Signatures

We certify that this report is a true representation of the results obtained from the tests of the equipment stated. We further certify that the measurements shown in this report were made in accordance with the procedures indicated and vouch for the qualifications of all Retlif Testing Laboratories personnel taking them.



Robert P. Warren
EMC Test Engineer



Richard J. Reitz
Laboratory Manager

Non-Warranty Provision

The testing services have been performed, findings obtained, and reports prepared in accordance with generally accepted laboratory principles and practices. This warranty is in lieu of all others, either expressed or implied.

Non-Endorsement

This test report contains only findings and results arrived at after employing the specific test procedures and standards listed herein. It is not intended to constitute a recommendation, endorsement or certification of the product or material tested. This test report may not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.



Retlif Testing Laboratories

Test Report No. R-9699

Test Program Summary

Report Number: R-9699
Customer: Utility Relay Company
Test Sample: Zero-Hertz Protective Relay
Part Number: B-203-SP2
Serial Number: 14

Test Method: Test Specification:

- RF Susceptibility: Ontario Hydro Standard C-5047-77.
- Dielectric Withstand: IEEE C37.90-1989.
- Surge: Ontario Hydro Standard A28M-82.

Mode of Operation:

Powered by 120 VAC, 60 Hz, monitoring DC shunt input with simulated adjustable 45mV shunt voltage. The Test sample current limit and pick up was 750 A and the instantaneous trip setting was set to 8000 A.

Susceptibility Criteria:

During all immunity testing, the EUT was monitored for:

1. False tripping of the output trip relay.
2. Test sample shuts down or resets.
3. "Pickup" LED remains clear (not illuminated) when power input is tested.

Test Methods:

The following table depicts the test methods which were performed on the Zero-Hertz Protective Relay and the corresponding test results:

Paragraph	Test Method	Test Results
6.1	Radiated RF Susceptibility	Complied
6.2	Dielectric Withstand	Complied
6.3	Surge Immunity	Complied



Retlif Testing Laboratories

Test Report No. R-9699

Revision History

Revision

Date

Pages Affected



Retlif Testing Laboratories

Test Report No. R-9699

1.0 Scope

The purpose of this test program was to determine the compliance of a Zero-Hertz Protective Relay, Part Number B-203-SP2, to the requirements of Ontario Hydro Standard C-5047-77, IEEE C37.90-1989 and Ontario Hydro Standard A28M-82. The individual test methods performed on the Zero-Hertz Protective Relay are outlined in paragraph 6.0 of this test report.

2.0 Applicable Documents

The following documents form a part of this test report to the extent specified herein:

RCM-001, Retlif Testing Laboratories, Calibration Manual.

RQM-001, Retlif Testing Laboratories, Quality Assurance Manual.

ANSI/NCSL Z-540, Calibration Laboratories and Measuring Test Equipment – General Requirements.

MIL-STD-285, Attenuation Measurements for Enclosures, Electromagnetic Shielding for Electronic Test Purposes, Method of.

MIL-F-15733F, Filters, Radio Frequency Interference, General Specifications for.

MIL-STD-220A, Insertion Loss Measurement, Method of.

Ontario Hydro Designation Standard No. C-5047-77, Specification for testing Susceptibility of electronic equipment to radiated interference.

IEEE C37.90-1989, Dielectric Withstand.

Ontario Hydro Designation Standard No. A-28M-82, Oscillatory Transient Interference Immunity Test.



Retlif Testing Laboratories

Test Report No. R-9699

3.0 General Requirements

3.1 Test Environment

All testing was performed at the Retlif Testing Laboratories, Ronkonkoma, New York facility. Each test method was performed in the environment specified within the test standard. Where the test environment deviated from that specified, it is noted in the applicable test method.

3.1.1 Shielded Enclosures

All testing which required the use of a shielded enclosure was performed in a solid steel, double wall, modular type. The attenuation characteristics of the enclosure were in accordance with MIL-STD-285. All input power lines to the enclosure was filtered utilizing filters manufactured in accordance with MIL-F-15733F and tested in accordance with MIL-STD-220A.

3.1.2 RF Absorber Material

Test methods requiring anechoic treatment, were performed in a room treated with a combination of pyramidal carbon impregnated foam absorber and ferrite tile. The RF absorber was placed above, behind and on both sides of the EUT, and behind the radiating or receiving antenna.

3.1.3 Ground Plane

A brass ground plane, 0.5 millimeters thick, 1.0 meters square or more in area with a minimum width of 0.75 millimeters was utilized. When a shielded enclosure was employed, the ground plane was bonded to the shielded enclosure at intervals no greater than one meter and at both ends of the ground plane.

3.2 Test Instrumentation

A listing of all test instrumentation utilized is contained within each applicable test method. These listings indicate the model, manufacturer, frequency range, last calibration date and calibration due date of all instrumentation utilized. All instrumentation utilized was calibrated prior to use in accordance with the procedures set forth in Retlif Testing Laboratories standard manuals RCM-001 and RQM-001, which are in accordance with the requirements of ANSI/NCSL Z-540.

3.2.1 Grounding

Interference measuring instruments were physically grounded with only one connection. When an antenna was used, the measuring instrument was connected to ground with only the power cord ground (green wire). When a copper-bonding strap was used on either the measuring instrument or the antenna (such as the rod counterpoise), neither the power cord ground nor the instrument ground terminals were used.

3.2.2 Measurement Accuracy

The accuracy of all measurements is as follows:

- Frequency: $\pm 2\%$
- Amplitude, measurement receiver: ± 2 dB
- Amplitude, measurement system: ± 3 dB
- Distance: $\pm 5\%$
- Time (waveforms): $\pm 5\%$



Retlif Testing Laboratories

Test Report No. R-9699

4.0 Test Sample Description

4.1 General

The test sample was a Zero-Hertz Protective Relay, Part Number B-203-SP2. The Zero-Hertz Protective Relay was powered by 120 VDC, 60 Hz. The test sample measured 10 centimeters long by 17 centimeters wide by 6 centimeters high and weighed 1 pound. Utility Relay Company of Chagrin Falls, Ohio, manufactured the Zero-Hertz Protective Relay.

4.2 Configuration

For all test methods, the Zero-Hertz Protective Relay was configured as shown in the General Test Setup drawing, Figure 3. All system cabling including cable length, routing and type were as specified in the table below:

Zero-Hertz Protective Relay Cable Configurations

EUT Port Numbers	Cable Length	Cable Type	Routed to
*DC Shunt Input	*10cm	Unshielded 18 AWG	9V Battery
Actuator Output	15cm	Unshielded 16 AWG Cable	Trip Relay
AC Power Input	1m	Unshielded 16 AWG	120 VAC, 60 Hz Mains


*Note: For the Surge test, DC Shunt Input, the battery fixture was replaced with a 7m, Unshielded 18 AWG Cable shorted at the opposite end.



Retlif Testing Laboratories

Test Report No. R-9699

Figure 3
General Test Setup



Notes:

1. The power cable was 1 meter long.
2. The DC Shunt was connected to the battery as shown except when this input was subjected to the surge test. It was then replaced with a 7 meter cable which was shorted at the end.
3. The test sample was grounded at a bottom case screw via ground strap for the surge tests.



Retlif Testing Laboratories

Test Report No. R-9699

5.0 Test Sample Parameters

5.1 Mode of Operation

During the performance of all testing specified herein, the test sample was powered by 120 VAC, 60 Hz, monitoring DC shunt input with simulated adjustable 45mV shunt voltage. The Test sample current limit and pick up was 750 A and the instantaneous trip setting was set to 8000 A.

5.1.1 Support Equipment

The following support equipment was utilized to operate and monitor the Zero-Hertz Protective Relay:

Description	Manufacturer	Model Number	Serial Number
Trip Relay	Potter & Brumfield	KRPA-11AG-6	N/A

5.2 Performance Requirements

Any false tripping of the output trip relay was considered as a sign of Susceptibility. If the test samples shut down or reset and if the "Pickup" LED illuminates when the power inputs were tested, it was also considered as a sign of susceptibility.

5.2.1 Monitoring Equipment

The Zero-Hertz Protective Relay was monitored for susceptibility utilizing the test sample LCD display and the output trip relay.



Retlif Testing Laboratories

Test Report No. R-9699

6.0 Test Methods

The following test methods were performed on the Zero-Hertz Protective Relay in accordance with Ontario Hydro Standard C-5047-77, IEEE C37.90-1989 and Ontario Hydro Standard A28M-82:

Paragraph	Test Method	Test Results
6.1	Radiated RF Susceptibility	Complied
6.2	Dielectric Withstand	Complied
6.3	Surge Immunity	Complied

See the individual test methods contained in paragraphs 6.1 through 6.3 of this test report for a full description of the procedures utilized and test results obtained.



Retlif Testing Laboratories

Test Report No. R-9699

6.1 Radiated RF Susceptibility, 450 MHz

Purpose

The purpose of this test method was to verify the ability of the Zero-Hertz Protective Relay to withstand radiated electromagnetic fields at a frequency of 450 MHz generated from a 5-watt hand held radio.

Test Parameters

The radiated susceptibility test method had characteristics as shown in the table below:

Test Frequency	Limit	Test Position	Polarization
450 MHz	5.0 Watts	Front	Vertical, Horizontal, Perpendicular
450 MHz	5.0 Watts	Back	Vertical, Horizontal, Perpendicular
450 MHz	5.0 Watts	Left	Vertical, Horizontal, Perpendicular
450 MHz	5.0 Watts	Right	Vertical, Horizontal, Perpendicular
450 MHz	5.0 Watts	Top	Vertical, Horizontal, Perpendicular
450 MHz	5.0 Watts	Bottom	Vertical, Horizontal, Perpendicular

Test Setup

The Zero-Hertz Protective Relay was configured in accordance with the General Test Setup drawing, Figure 3. The test instrumentation was configured in accordance with Figure 4 and as shown in the following photographs. The Zero-Hertz Protective Relay was configured in a shielded enclosure employing RF absorber material.

Test Procedure

With the test instrumentation and the Zero-Hertz Protective Relay configured as stated above, the following steps were performed:

1. The Zero-Hertz Protective Relay was placed inside of a shielded chamber.
2. With the Zero-Hertz Protective Relay operating as described in Paragraph 5.1 herein, the front surface of the test sample was probed with the 5-Watt Hand Held Radio.
3. The 5-Watt Hand Held Radio was maintained at a minimum distance of six inches from the surface of the Zero-Hertz Protective Relay, in both the horizontal and vertical polarities.
4. During this probing, the 5-Watt Hand Held Radio was continuously keyed up.
5. The Zero-Hertz Protective Relay was continuously monitored for susceptibility criteria as described in Paragraph 5.2 herein.
6. Steps 1 through 5 were repeated for each surface of the test sample and for the horizontal, vertical and perpendicular polarizations.

Test Results

The Zero-Hertz Protective Relay was found to comply with the specified requirements for the Radiated RF Susceptibility test method.


See the following single (1) data sheet for a complete presentation of the test result obtained.



Retlif Testing Laboratories

Test Report No. R-9699

**Test Photograph
Radiated RF Susceptibility**




Test Setup




Retlif Testing Laboratories

Test Report No. R-9699

Figure 4
Radiated RF Susceptibility, 450 MHz



- 1. Power Cable was 1 meter long
- 2. Hand Held Radio was maintained at a minimum distance of six inches from the EUT

	Retlif Testing Laboratories
	Test Report No. R-9699

EQUIPMENT LIST

RF Radiated Susceptibility

EN	Type	Manufacturer	Description	Model No.	Cal Date	Due Date
224	Shielded Enc. (24x20x12)	Universal Shielding	100dB, 14kHz -	1	4/30/2002	4/30/2003
n/a	5 Watt Hand Held Radio	Riccom	5W Radio	JBX-455	n/a	n/a



RetIf Testing Laboratories

Test Report No. R-9699

6.2 Dielectric Tests

Purpose

The purpose of this test was to determine the dielectric properties between the case of the Zero-Hertz Protective Relay and its power input leads.

Test Points

Test Points	Voltage Applied
Mains - Chassis	1500 VAC
DC Shunt - Input - Chassis	1500 VAC

Test Setup

The test instrumentation and the Zero-Hertz Protective Relay were configured as shown in the attached photograph.

Test Procedure

With the test instrumentation and the Zero-Hertz Protective Relay configured as stated above, the following steps were performed:

Dielectric Withstand

1. The dielectric meter was connected between the mains and chassis ground of the Zero-Hertz Protective Relay.
2. Voltage was gradually increased from 0 to 1500 VAC at a rate of 250 V/Sec.
3. Once the voltage was attained, conditions were maintained for 1 minute.
4. The Zero-Hertz Protective Relay was monitored for any degradation or dielectric breakdown.
5. The leakage current was measured and recorded in millamperes.
6. Steps 2 through 5 were repeated with the dielectric meter connected between the DC Shunt input and Chassis ground.

Test Results

The Zero-Hertz Protective Relay was found to comply with the specified requirements of IEEE C39.90-1989 Dielectric test method.


See the following single (1) data sheet for a complete presentation of the test results obtained.




Retlif Testing Laboratories

Test Report No. R-9699

Test Photographs
Dielectric Withstand



View #1



View #2



Retlif Testing Laboratories

Test Report No. R-9699

EQUIPMENT LIST

Dielectric Withstand Test

EN	Type	Manufacturer	Description	Model No.	Cal Date	Due
224	Shielded Enc. (24x20x12)	Universal Shielding	100dB, 14kHz -	1	4/30/2002	4/30/2003
7012	AC/DC Hipot Tester	Quad Tech	N/A	Sentry 20	5/10/2002	5/10/2003



Retlif Testing Laboratories

Test Report No. R-9699

RETLIF TESTING LABORATORIES, INC.

DIELECTRIC TEST DATA SHEET

CUSTOMER: Utility Relay Company
TEST SAMPLE: Zero Hertz Protective Relay
TEST SPECIFICATION: IERE C37.90-1989
TECHNICIAN: S. Carley *SCW*
PRE-CONDITIONING: n/a

JOB NUMBER: R-9699
MODEL: n/a
SERIAL NUMBER: n/a
PART NUMBER: B-203-SP2
DATE: November 18, 2002
FAULT APPLIED: n/a

TEST POINT	VOLTAGE APPLIED	LEAKAGE CURRENT
1 EUT Chassis to Power Input Connector	1500 VAC	0.51 mA
2 EUT Chassis to DC Shunt Input	1500 VAC	0.06 mA
3		
4		
5		

LAB NOTES:

VOLTAGE INCREASE	TEST LOG
Dielectric Withstand	250 volts was injected between the EUT case and each of the leads listed above. The voltage was uniformly increased at a rate of 250 volts/sec to 1500 volts and maintained for a period of 1 minute. After both leads were tested, the test sample was verified to be working correctly.

RESULTS:

The test sample did not exhibit any malfunction, degradation of performance or deviation from specified indication beyond the tolerances given in the individual equipment specifications or approved test plan when tested in accordance with the above stated test method.
--

6.3 Surge Test

Purpose

The purpose of this test method was to determine if the Zero-Hertz Protective Relay was so constructed as to have an adequate level of intrinsic immunity to common and differential mode surges applied to input power leads, enabling the Zero-Hertz Protective Relay to operate as intended.

Test Parameters

The critical parameters of the applied surge waveform are shown below:

Waveform:	1 MHz Damped Sine
Voltage:	2.5 kV Differential Mode, 2.5 kV Common Mode
Pulse Repetition Rate:	120 Hz
Burst Width:	4 seconds
Pulses Applied:	3 spaced 1 minute apart
Source Impedance:	150 ohms

Leads Tested

The following leads on the Zero-Hertz Protective Relay were tested separately in order to demonstrate compliance to the above requirements:

- | | |
|--------------------------------------|--------------------------------------|
| - 120 VAC, 60 Hz - Hot to Ground | - DC Shunt Input - Hot to Ground |
| - 120 VAC, 60 Hz - Neutral to Ground | - DC Shunt Input - Neutral to Ground |
| - 120 VAC, 60 Hz - Hot to Neutral | - DC Shunt Input - Hot to Neutral |

Test Setup

The test instrumentation and Zero-Hertz Protective Relay were configured as shown in the attached photographs and detailed in Paragraph 4.2 herein. This configuration was based upon the general test setup shown in Retlif Testing Laboratories Drawing Number R61000-4-5/P and the requirements of Ontario Hydro Standard A28M-82. The Zero-Hertz Protective Relay was placed on an 80 cm high wooden test stand above the test enclosure floor. The test stand was situated such that it was at least 50 cm from the enclosure wall. The power leads were routed through the internal coupling/decoupling network of the transient surge generator.

Test Procedure

After verification of the transient generator output parameters, the following steps were performed:

1. The Zero-Hertz Protective Relay was powered from AC line voltage, which was supplied through the surge generator.
2. The surge generator was configured to apply 2.5 kV transients.
3. Three positive 2.5 kV transients were applied to the AC leads in the coupling modes specified on the test data sheets at a repetition rate not exceeding 1 PPM.
4. The surge generator was configured to apply negative surges and step 3 was repeated.
5. Steps 1 through 4 were repeated for each AC Input of the Zero-Hertz Protective Relay and each DC Shunt Input.

Test Results


The Zero-Hertz Protective Relay complied with the requirements specified for this test method. The test sample did not exhibit any malfunction or degradation of performance beyond that allowed under Ontario Hydro Standard A28M-82 when subjected to the 2.5 kV surge specified above. See the following five (5) data sheets for a full presentation of the results obtained.




Retlif Testing Laboratories

Test Report No. R-9699

Test Setup Photograph
Surge



Power lead




Shunt lead



Retlif Testing Laboratories

Test Report No. R-9699

General Setup Drawing - R61000-4-5/P
Surge Test Setup



Retlif Testing Laboratories

Test Report No. R-9699

EQUIPMENT LIST

Surge Test

EN	Type	Manufacturer	Description	Model No.	Cal Date	Due
1127	Oscilloscope	Tektronix	DC - 500 MHz	2440	5/20/2002	5/20/2003
3806	Coupling/Decoupling Net	Velonex	N/A	V-2269	11/21/2001	11/21/2002
3807	Surge Transient Generator	Velonex	N/A	515	11/21/2001	11/21/2002
424	Graphics Plotter	Hewlett Packard	N/A	7470A	3/14/2002	3/14/2003




Retlif Testing Laboratories

Test Report No. R-9699

CH1 1V A 1μs 31.3mV? CH1

1.1765MHz



CH1 MAX = 2.60 V

CH1 gnd

Customer:	Utility Relay Company
Part Number:	Zero Hertz Protective Relay
Order Date:	Part No.: B-203-S72
Test Method:	Surge Test
Notes:	Plot of a 1 MHz waveform with a peak voltage of 2620 Volts (1200 : 1 Probe Factor)
Test Results:	1000 x 2.6 Volts = 2600 Volts
Date:	November 18, 2002
Time:	2:00:00
Operator:	SC / RPW
Page:	1
Total Pages:	3




Retlif Testing Laboratories

Report No. R-9699

CH1 1V A 50ns 46.9mV? CH1

35.000ns



Customer:	Utility Relay Company
Product:	Zero Hertz Protective Relay
Part No.:	B-203-SP2
Test Method:	Surge Test
Condition:	Plot of the 35 nanosecond rise time for a 1 MHz waveform at 2500 Volts (1000:1 Probe Factor)
Input:	1000 x 2.5Volts = 2500 Volts
Date:	November 18, 2002
Page:	SC / RPW
Page:	2
Page:	5




Retlif Testing Laboratories

Report No. R-9699

CH1 1V A 1e 1.28 V7 CH1

4.0100 s



CH1gnd

Customer:	Utility Relay Company
Test Sample:	Zero Hertz Protective Relay
Part No.:	B 243-SP2
Test Method:	Surge Test
Notes:	Plot. of a 1 MHz surge with a rep rate of 120 Hz over a total duration of 4 seconds at a cal level of 2500 Volts
	(*020) * Probe Factor: 1000 x 2.5 Volts = 2500 Volts
Date:	November: 18, 2002
Page:	SC / RPW / <i>ADJ</i> / 3 / 3



Retlif Testing Laboratories

Report No. R-9699